

	Document Title:	Doc No:	FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 1110 - 101.0
 Issue Date: 12/10/2020
 Revision Date: 12/10/2020
 Expiration Date: 12/10/2024
 Company Code: 1110

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Otiima USA 367 E. Alondra Blvd Gardena, CA 90248 USA	Model: Sliding Patio Door (OXXX) DP70 Operator Type: SGD Config: No, GS - 9/16" Ann Lami IG Max Width: 200 Max Height: 120

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-17	Class LC-PG70 5086x3048 (200x120)-Type SGD

Qualifying Test Information:	
Test Report No:	ATI-I7564.04-303-18
Test Report Expiration:	12/10/2024

Authorized Signature:

Keystone Certifications, Inc.
 145 Limekiln Rd. Suite 100B
 New Cumberland, Pennsylvania 17070
 Phone: 717-932-8500
 Fax: 717-932-8501

	Document Title:	Doc No:	FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 1110 - 102.0
 Issue Date: 12/10/2020
 Revision Date: 12/10/2020
 Expiration Date: 12/10/2024
 Company Code: 1110

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Otiima USA 367 E. Alondra Blvd Gardena, CA 90248 USA	Model: Sliding Patio Door (OXXX) DP55 Operator Type: SGD Config: No, GS - 9/16" Ann Lami IG Max Width: 200 Max Height: 120

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-17	Class LC-PG55 5086x3048 (200x120)-Type SGD, WTP=10.7

Qualifying Test Information:	
Test Report No:	ATI-I7564.04-303-18
Test Report Expiration:	12/10/2024

Authorized Signature:

Keystone Certifications, Inc.
 145 Limekiln Rd. Suite 100B
 New Cumberland, Pennsylvania 17070
 Phone: 717-932-8500
 Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 1110 - 103.0
Issue Date: 12/10/2020
Revision Date: 12/10/2020
Expiration Date: 12/10/2024
Company Code: 1110

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Otiima USA 367 E. Alondra Blvd Gardena, CA 90248 USA	Model: Sliding Patio Door (OXXX) DP30 Operator Type: SGD Config: No, GS - 9/16" Ann Lami IG Max Width: 200 Max Height: 120

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-17	Class LC-PG30 5086x3048 (200x120)-Type SGD, WTP=10.7

Qualifying Test Information:	
Test Report No:	ATI-I7564.04-303-18
Test Report Expiration:	12/10/2024

Authorized Signature:

Keystone Certifications, Inc.
145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title:	Doc No:	FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 1110 - 104.0
 Issue Date: 12/10/2020
 Revision Date: 12/10/2020
 Expiration Date: 12/10/2024
 Company Code: 1110

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Otiima USA 367 E. Alondra Blvd Gardena, CA 90248 USA	Model: Sliding Patio Door (OXXX) DP25 Operator Type: SGD Config: No, GS - 9/16" Ann Lami IG Max Width: 200 Max Height: 120

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-17	Class LC-PG25 5086x3048 (200x120)-Type SGD, WTP=10.7

Qualifying Test Information:	
Test Report No:	ATI-I7564.04-303-18
Test Report Expiration:	12/10/2024

Authorized Signature:

Keystone Certifications, Inc.
 145 Limekiln Rd. Suite 100B
 New Cumberland, Pennsylvania 17070
 Phone: 717-932-8500
 Fax: 717-932-8501